


Client's name / Tên khách hàng : CÔNG TY CỔ PHẦN VIET TILES
 Client's address / Địa chỉ : 91 TRẦN NÃO, KP4, PHƯỜNG BÌNH AN, QUẬN 2, TP.HCM

The following sample(s) was/were submitted and identified by the client as:

Các thông tin nhận dạng mẫu do khách hàng cung cấp:

Name of sample / Tên mẫu : BREEZE CEMENT BLOCK / GẠCH BÔNG GIÓ
 290 x 290 x 90 (mm)
 Quantity / Số lượng mẫu : 01 sample / mẫu
 Date of receiving / Ngày nhận mẫu : 19-Mar-2019
 Date of testing / Ngày thử nghiệm : From / từ 19-Mar-2019 to / đến 25-Mar-2019
 Test result / Kết quả thử nghiệm : See next page(s) / Xem trang sau



SGS authenticate the photos on original report only/ SGS chỉ xác thực các hình ảnh trong báo cáo chính thức

Signed for and on behalf of
 SGS Vietnam LTD



To Đức Tien
 Technical Manager
 Industrial Services

"This document is issued by the Company under its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.vn/en/terms-and-conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.vn/en/terms-and-conditions/terms-e-document>. Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested only."

038834

Characteristic Tên chỉ tiêu	Unit Đơn vị	Test method Phương pháp thử	Test result Kết quả thử nghiệm
A. Basic dimension / Kích thước cơ bản			
• Length / Chiều dài cạnh 1	mm	TCVN 6065 : 1995 Phần 5.2	292.1
• Length / Chiều dài cạnh 2	mm		291.8
• Thickness / Chiều dày	mm		89.7
• Rectangularity Độ vuông góc	mm		0.1
B. Water absorption (*) Độ hút nước	%	TCVN 6355 : 2009 Phần 4	11.4
C. Compressive strength (*) Cường độ nén	MPa	TCVN 6355 : 2009 Phần 2	1.9

Note:

(*) The test was accredited ISO 17025:2005 by VILAS / Chỉ tiêu được công nhận ISO 17025:2005 bởi VILAS.

ILAC: International Laboratory Accreditation / Tổ chức hợp tác công nhận Phòng thử nghiệm quốc tế.

MRA: Mutual Recognition Arrangement / Thỏa ước thừa nhận lẫn nhau.

ILAC-MRA -VILAS: VILAS is the full member and signatory of Mutual Recognition Arrangement with International Laboratory Accreditation / VILAS là thành viên đầy đủ và ký thỏa ước thừa nhận lẫn nhau với tổ chức công nhận phòng thử nghiệm quốc tế

*** END OF THE REPORT ***

"This document is issued by the Company under its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.vn/en/terms-and-conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.vn/en/terms-and-conditions/terms-e-document>. Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested only."

038835